



Interoffice Memorandum

April 10, 2020

TO: Mayor Jerry L. Demings  
and Board of County Commissioners

FROM: Joseph C. Kunkel, P.E., Director, Public Works Department

CONTACT PERSON: Humberto L. Castillero, P. E., PTOE, Interim Manager  
Traffic Engineering Division

PHONE NUMBER: (407) 836-7891

SUBJ: Installation of "No Parking" Signs on Stonebriar Way

Orange County Traffic Engineering Division has requested that "No Parking" signs be installed along the curves on both sides of Stonebriar Way.

Traffic Engineering staff performed a review of the on-street parking situation on Stonebriar Way and has confirmed that streets that allow parking on both sides of the street impact emergency apparatus from accessing certain portions of the community; thereby creating a public safety hazard. The Florida Fire Prevention Code, Section 18.2.3.4.1.1, requires that fire department access roads shall have an unobstructed width of no less than 20 feet. Also, the Florida Fire Prevention Code, Section 18.2.4.1.1, states that the required width of a fire department access road shall not be obstructed in any manner, including the parking of vehicles. Therefore, staff recommends the installation of "No Parking" signs.


Staff recommends that the Board approve the "No Parking" signs installation along the curves on both sides of Stonebriar Way.

**Action Requested: Approval of "No Parking" signs installation along the curves on both sides of Stonebriar Way. District 5.**

JCK/HLC/AHW/nad

Attachments

# Stonebriar Way Location Map



District 5: Commissioner Emily Bonilla