



Interoffice Memorandum

November 1, 2018

TO: Mayor Jerry L. Demings
and Board of County Commissioners

FROM:  Mark V. Massaro, P.E., Director, Public Works Department 

CONTACT PERSON: Christine N. Lofye, P. E., Manager 
Traffic Engineering Division

PHONE NUMBER: (407) 836-7890

SUBJ: **Installation of "No Parking" zones in the curves of Crystal Bay Lane
between addresses 714 to 806 and 920 to 951.**

Citizens within the Osprey Ridge community have expressed concerns related to the ability of emergency vehicles to access their homes when vehicles are parked on-street. The Orange County Fire Rescue Department reviewed the current on-street parking patterns on Crystal Bay Lane from Waterford Chase Parkway to Avalon Park Boulevard and has confirmed that allowing parking in the curves on Crystal Bay Lane impedes emergency apparatus from accessing certain portions of the community, thereby creating a public safety hazard.

Florida Fire Prevention Code, Section 18.2.3.4.1.1, requires that fire department access roads shall have an unobstructed width of no less than 20 feet. Also, the Florida Fire Prevention Code, Section 18.2.4.1.1, states that the required width of a fire department access road shall not be obstructed in any manner, including the parking of vehicles.

The Fire Marshal recommends approval of the establishment of "No Parking" zones on the north and south sides of Crystal Bay Lane between addresses 714 to 806 and 920 to 951.


Action Requested: Approval of "No Parking" signs installation in the curves of Crystal Bay Lane between addresses 714 to 806 and 920 to 951. District 4.

MVM/CNL/LT

Attachments



Crystal Bay Lane Consent Agenda Location Map



District 4: Commissioner Maribel Gomez Cordero